

| Test Data & Material Characteristics | | |
|---|---------------------|--|
| Hardscape Products Ltd. | Date of Certificate | |
| 25 | 11/12/2025 | |

BS EN 1339:2003 - Precast Concrete Paving Flags Requirements and Test Methods

Commercial name:

Textured Classic Modular

Place of manufacture:

Co.Meath, Ireland

Uses:

Internal and external flooring and / or roof covering



Website: https://hardscape.co.uk/

| Declared Performance | | | |
|---------------------------|-----------------|--------------------------------------|--|
| Characteristics | Value | Testing Method Standard | |
| Reaction to Fire | A1 | BS EN 1338:2003 (5.3.6.1) | |
| External Fire Performance | NPD | BS EN 1338:2003 (5.3.6.2) | |
| Emission of asbestos | No ACMs Present | BS EN 1338:2003 (4.2) | |
| Breaking strength | ≥ 3.5 MPa | BS EN 1338:2003 (5.3.3.1&2) | |
| Slip / skid resistance | > 45 | BS EN 1338:2003 (5.3.5.1&2) | |
| Thermal Conductivity | NPD | BS EN 1338:2003 (5.3.7)/ EN 13369 | |
| Durabilty | Satisfactory | BS EN 1338:2003 (5.3.3.3) | |
| Light Reflectance Value | NPD | BS 8493:2008+A1:2010 | |

| All tests conform to the specific standard requirements and test methods for the material types as detailed above: | Signed: | Sal |
|--|---------|-----|

Products are offered in line with the requirements of Attestation Level 4 as designated under the Construction Products Regulations (2011) Annex V. Type testing, routine testing and Factory Production Control documents have been developed and issued for this series of products.

Hardscape Products Ltd., Eagley House, Deakins Business Park, Egerton, Bolton, Lancashire, BL7 9RP